

CERTIFICATE No. 9214

SERVICE CERTIFICATE
Hutton Fire Protection Ltd.
 Unit A, Vue Business Park, Ladysmith Street,
 Hartlepool TS25 1PX
 Tel: 01429 260 413
 Website: www.huttonfireprotection.com
 Email: hhutton@huttonfireprotection.co.uk



INVOICE ADDRESS

BELIEVE HOUSING

LOCATION ADDRESS

ALCOTE HOUSE,
 SHOTTON COLLIERY

Invoice No.

Delivery/Service Date 1/5/2024

Customer Order No.

| DESCRIPTION | TOTAL SERVICED | CON'D | RECHARGED | O/A | PTR | O/A | NEW EQUIP | O/A |
|-----------------------|----------------|-------|-----------|-----|-----|-----|-----------|-----|
| WATER 9L | | | | | | | | |
| FOAM AFFF 1L | | | | | | | | |
| FOAM AFFF 2L | | | | | | | | |
| FOAM AFFF 3L | | | | | | | | |
| FOAM AFFF 6L | 2 | | | | | | | |
| FOAM AFFF 9L | | | | | | | | |
| CO ₂ 2kg | 2 | | | | 1 | | | |
| CO ₂ 5kg | | | | | | | | |
| CO ₂ OTHER | | | | | | | | |
| POWDER 1KG | | | | | | | | |
| POWDER 2KG | | | | | | | | |
| POWDER 4KG | | | | | | | | |
| POWDER 6KG | | | | | | | | |
| POWDER 9KG | | | | | | | | |
| POWDER 12KG | | | | | | | | |
| 6LTR CLASS F | | | | | | | | |
| 3LTR WATER ADDITIVE | | | | | | | | |
| 6LTR WATER ADDITIVE | | | | | | | | |
| TOTAL EXTINGUISHERS | 4 | | | | 1 | | | |
| TOTAL HOSE REELS | | | | | | | | |
| TOTAL FIRE BLANKETS | 1 | | | | | | | |

| SPARE PARTS FITTED | QTY | O/S |
|----------------------------------|-----|-----|
| HEADCAP ASSEMBLY | | |
| HEADCAP SEAL | | |
| HOSE/NOZZLE SEAL | 2 | |
| SAFETY CLIP/PIN | 1 | |
| VALVE ASSY (CO ₂) | 1 | |
| HORN ASSY (CO ₂) | 1 | |
| HOSE & HORN ASSY CO ₂ | | |
| TAMPER INDICATOR | 4 | |
| GAUGE TEST | 2 | |
| BURSTING DISC | 1 | |
| HOSE REEL NOZZLE | | |
| WORM DRIVE CLIP | | |
| CARTRIDGE 55GM | | |
| CARTRIDGE 75GM | | |
| CARTRIDGE OTHER | | |
| WALL BRACKET | | |
| EXTINGUISHER ID SIGN | | |
| MISC. O. RINGS CO ₂ | 1 | |
| EXTINGUISHER TESTED BY DISCHARGE | | |
| ATTENDANCE FEE | | |
| CALL OUT FEE | | |
| DELIVERY CHARGE | | |
| LABOUR | | |

ENGINEERS COMMENTS
 REMEDIAL WORK REQ
 1x 2kg CO₂ EXT - DUE PRESSURE TEST
 COMPLETED @ TIME OF SERVICE.

Engineer's Signature *D. Golightly* Print Name D. GOLIGHTLY

Customer's Signature Print Name

Position Date Signed

Customer Copy: White A/C: Blue

| | | |
|-------|--|--|
| TOTAL | | |
| VAT | | |
| TOTAL | | |

SERVICE
 CALL OUT



Inspection by the user: It is recommended that regular visual inspections of all extinguishers be carried out by the user or by user's representative. The frequency of inspections by the user should be not less than monthly and, when circumstances require, inspections should be carried out more frequently. Apart from the non confirming extinguishers as recorded, all portable fire extinguishers have been inspected and serviced in accordance with BS503 PT9 and BS5306 Part 3. Terms Subject to HUTTON FIRE PROTECTION Standard published conditions of sale, applicable to the goods or services described above. Copy available on request.