



1. SYSTEM DETAILS

Contract No: 1001036520 **System Category** **Inspection Frequency** 2 /Year

Client: BELIEVE HOUSING LIMITED

Address: WHEATBOTTOM
CROOK
DURHAM
DL15 9HB

Routine Inspection History	
Date	% Complete
12/07/23	50
30/01/23	50

2. INSPECTION DETAILS

Inspection Type: Periodic **% Complete on Visit:** 50 **Zones on System:** 4

Zones Tested: Zones 1-4

Further Details: Routine inspection to 50% all devices, tested and working correctly

Batteries Tested: Yes No

Variations from the recommendations of Clause 45 of BS5839-1:2017 periodic or annual inspection & test: Yes No

Details:

Relevant details of work carried out & faults identified have been entered in the system log book: Yes No Logbook available

3. FALSE ALARMS

During the past 12 months false alarms have occurred, number of devices No Records

The above number of false alarms equates to false alarms per 100 automatic fire detectors per annum

4. RECOMMENDATIONS

A subsequent visit is required to complete the following work: Yes No

5. CERTIFICATION

I, being the competent person responsible (as indicated by my signature below) for the fire detection and alert system, as identified above, CERTIFY that the said work for which I have been responsible complies to the best of my knowledge and belief with the recommendations of (ROI: IS.3218:2013) or clause 45 of BS5839-1:2017, *except for the variations, if any, stated in this certificate.

Name: GARY JEWETT

Position: Service Engineer

BAFE SP203 Scheme Registration No: 101240

Signature:

Date: 03/01/24