

CERTIFICATE No. 8841

SERVICE CERTIFICATE

Hutton Fire Protection Ltd.
 Unit A, Vue Business Park, Ladysmith Street,
 Hartlepool TS25 1PX
 Tel: 01429 260 413
 Website: www.huttonfireprotection.com
 Email: hhutton@huttonfireprotection.co.uk



INVOICE ADDRESS

BELIEVE HOUSING.

LOCATION ADDRESS

BELIEVE HOUSING.
 20 WHEATBOTTOM COMM CENTRE.
 CROOK

Invoice No.

Delivery/Service Date 11/12/2023

Customer Order No.

| DESCRIPTION | TOTAL SERVICED | CON'D | RECHARGED | O/A | PTR | O/A | NEW EQUIP | O/A |
|---|----------------|-------|-----------|-----|-----|-----|-----------|-----|
| WATER 9L | | | | | | | | |
| FOAM AFFF 1L | | | | | | | | |
| FOAM AFFF 2L | | | | | | | | |
| FOAM AFFF 3L | | | | | | | | |
| FOAM AFFF 6L | | | | | | | | |
| FOAM AFFF 9L | | | | | | | | |
| CO2 2kg | | | | | | | | |
| CO2 5kg | | | | | | | | |
| CO2 OTHER | | | | | | | | |
| POWDER 1KG | | | | | | | | |
| POWDER 2KG | | | | | | | | |
| POWDER 4KG | | | | | | | | |
| POWDER 6KG | | | | | | | | |
| POWDER 9KG | | | | | | | | |
| POWDER 12KG | | | | | | | | |
| 6LTR CLASS F | | | | | | | | |
| 3LTR WATER ADDITIVE | | | | | | | | |
| 6LTR WATER ADDITIVE | | | | | | | | |
| TOTAL EXTINGUISHERS | | | | | | | | |
| TOTAL HOSE REELS | | | | | | | | |
| TOTAL FIRE BLANKETS | 1 | | | | | | | |
| ENGINEERS COMMENTS | | | | | | | | |
| RECOMMENDATIONS - | | | | | | | | |
| 1x 6Ltr WATER EXT } AS COVER FOR LOUNGE AREA. | | | | | | | | |
| 1x 2KG CO2 EXT } + ID SIGNS | | | | | | | | |
| 1x 2Ltr FOAM EXT - + ID SIGN - COVER FOR KITCHEN. | | | | | | | | |

| SPARE PARTS FITTED | QTY | O/ |
|----------------------------------|-----|----|
| HEADCAP ASSEMBLY | | |
| HEADCAP SEAL | | |
| HOSE/NOZZLE SEAL | | |
| SAFETY CLIP/PIN | | |
| VALVE ASSY (CO2) | | |
| HORN ASSY (CO2) | | |
| HOSE & HORN ASSY CO2 | | |
| TAMPER INDICATOR | | |
| GAUGE TEST | | |
| BURSTING DISC | | |
| HOSE REEL NOZZLE | | |
| WORM DRIVE CLIP | | |
| CARTRIDGE 55GM | | |
| CARTRIDGE 75GM | | |
| CARTRIDGE OTHER | | |
| WALL BRACKET | | |
| EXTINGUISHER ID SIGN | | |
| MISC. O. RINGS | | |
| EXTINGUISHER TESTED BY DISCHARGE | | |
| ATTENDANCE FEE | | |
| CALL OUT FEE | | |
| DELIVERY CHARGE | | |
| LABOUR | | |

Engineer's Signature *D. Golightly* Print Name **D. GOLIGHTLY**
 Customer's Signature *N/A* Print Name *N/A*
 Position Date Signed

| | |
|--------------|--|
| TOTAL | |
| VAT | |
| TOTAL | |

Customer Copy: White A/C: Blue

Inspection by the user: It is recommended that regular visual inspections of all extinguishers be carried out by the user or by user's representative. The frequency of inspections by the user should be not less than monthly and, when circumstances require, inspections should be carried out more frequently. Apart from the non confirming extinguishers as recorded, all portable fire extinguishers have been inspected and serviced in accordance with BS503 PT9 and BS5306 Part 3. Terms Subject to HUTTON FIRE PROTECTION Standard published conditions of sale, applicable to the goods or services described above. Copy available on request.

