

CERTIFICATE No. 9212

**SERVICE CERTIFICATE**  
**Hutton Fire Protection Ltd.**  
 Unit A, Vue Business Park, Ladysmith Street,  
 Hartlepool TS25 1PX  
 Tel: 01429 260 413  
 Website: www.huttonfireprotection.com  
 Email: hhutton@huttonfireprotection.co.uk



INVOICE ADDRESS

BELIEVE HOUSING

LOCATION ADDRESS

ROBINSON HOUSE,  
 HORDEN COLLIERY

Invoice No. ....  
 Delivery/Service Date 11/5/2024  
 Customer Order No. ....

DESCRIPTION	TOTAL SERVICED	CON'D	RECHARGED	O/A	PTR	O/A	NEW EQUIP	O/A
WATER 9L								
FOAM AFFF 1L								
FOAM AFFF 2L								
FOAM AFFF 3L								
FOAM AFFF 6L	1							
FOAM AFFF 9L								
CO <sub>2</sub> 2kg	6				1			
CO <sub>2</sub> 5kg								
CO <sub>2</sub> OTHER								
POWDER 1KG								
POWDER 2KG								
POWDER 4KG								
POWDER 6KG								
POWDER 9KG								
POWDER 12KG								
6LTR CLASS F								
3LTR WATER ADDITIVE								
6LTR WATER ADDITIVE								
TOTAL EXTINGUISHERS	7				1			
TOTAL HOSE REELS								
TOTAL FIRE BLANKETS	1							

SPARE PARTS FITTED	QTY	O/S
HEADCAP ASSEMBLY		
HEADCAP SEAL		
HOSE/NOZZLE SEAL		
SAFETY CLIP/PIN	1	
VALVE ASSY (CO2)	1	
HORN ASSY (CO2)	1	
HOSE & HORN ASSY CO2		
TAMPER INDICATOR	7	
GAUGE TEST	1	
BURSTING DISC	1	
HOSE REEL NOZZLE		
WORM DRIVE CLIP		
CARTRIDGE 55GM		
CARTRIDGE 75GM		
CARTRIDGE OTHER		
WALL BRACKET		
EXTINGUISHER ID SIGN		
MISC. O. RINGS CO2	5	

ENGINEERS COMMENTS  
 1x 2kg CO<sub>2</sub> EXT + ID SIGN - NEEDS WALL MOUNTING  
 O/S LAUNDRY RM - REMOVED FOLLOWING IN HOUSE DECORATING. REC SINGLE STAND + ID

EXTINGUISHER TESTED BY DISCHARGE		
ATTENDANCE FEE		
CALL OUT FEE		
DELIVERY CHARGE		
LABOUR		

Engineer's Signature *D Gougherty* Print Name **D GOUGHERTY**  
 Customer's Signature ..... Print Name .....  
 Position ..... Date Signed .....

TOTAL		
VAT		
TOTAL		

Customer Copy: White A/C: Blue

Inspection by the user: It is recommended that regular visual inspections of all extinguishers be carried out by the user or by user's representative. The frequency of inspections by the user should be not less than monthly and, when circumstances require, inspections should be carried out more frequently. Apart from the non confirming extinguishers as recorded, all portable fire extinguishers have been inspected and serviced in accordance with BS503 PT9 and BS5306 Part 3. Terms Subject to HUTTON FIRE PROTECTION Standard published conditions of sale, applicable to the goods or services described above. Copy available on request.

