

# Portable Appliance Testing Documentation

## Client Details

Believe Housing  
Robinson House  
Park Lane  
Horden  
SR8 4DD

## Test Period Commencing

16-Aug-2024

Order Number 7463

Certificate Number -007035

Company Contact Pamela Wilson

## Testing Carried out by

Durham PAT Testing  
21 Leesfield Road  
Meadowfield  
Durham  
DH7 8NJ  
Phone: 0191 3781189  
Mobile: 07512303393  
Email: info@durhampattesting.co.uk

**DURHAM**  
**PAT TESTING**

## Portable Appliance Test Reports Guidance Notes

### Section 1: Folder Cover

The cover contains your details and the date(s) work was carried out

It will also tell you your certificate number

### Section 2: Guidance Notes

See notes below

### Section 3: Report Recommendations

This will tell you of any potential risks seen during testing or any testing that was unable to be carried out

### Section 4: Passes and Fails

This is your report of all tests carried out. It is in sections by location on your site.

A description of each appliance is given, it's test date and tests carried out. Each appliance number corresponds to the label number on the equipment.

Any failed appliances will be marked in red.

All appliances are visually inspected and in addition will include:

*Class I-Earth Continuity and Insulation Resistance*

*Class I Leads-Earth Continuity, Insulation Resistance and Polarity*

*Class II -Insulation Resistance*

*Class III-Visual Inspection only*

*Any failed appliances will include the reasons for the failure and will be marked in red*

### Section 5: Certificate

This is your certificate; you can display it if you wish. It shows a 'valid until' date. This is based on your risk assessment and is shown as 12 months unless otherwise informed

## Inspection and Testing of Electrical Equipment Report Guidance Notes

We have completed **Portable Appliance Testing**; the process of "PAT" is carried out under the guidelines of the **Inspection and Testing of Electrical Equipment**, issued by the Institution of Electrical Engineering.

This document, reports our findings. The Guidance Notes advise you about what you need to know.

1. Our work has been carried out in accordance with the requirements for the Electricity at Work Act 1989, the recommendations of the Health and Safety at Work Act 1974, the guidelines of the IEE Code of Practice, and the standards of the PAT Testing Network.
2. The Inspections and Testing has been completed based on your instructions, to the requirements specified by you. If you haven't made any specifications other than for us to complete the work, then it has been done to the usual standards.
3. In section 3, we have addressed any areas of concern or included any specific requirements from you that need to be included in the report. If there is nothing to report this section will be blank.
4. Section 4 is our report for any appliances that failed our inspection; they have either been

repaired or retested, or can't be repaired by us. Our recommendations are in the report. If you don't have a record of failed appliances then you should assume your appliances all passed. Appliances that fail completely should be removed from service and repaired (then arrange for us to return to re-test) or disposed of.

5. Determining when the next inspections should be done is your responsibility; we will make our recommendations but the final decision is yours. Unless you tell us otherwise we will presume inspections are to be carried out annually, and our reports will reflect this.

# PAT Report Recommendations For all Sites and Locations

| CLIENT DETAILS |  |
|----------------|--|
| Company Name:  | Believe Housing                                  |
| Address:       | Robinson House<br>Park Lane<br>Horden<br>SR8 4DD |



| DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING |   |            |   |
|--|---|------------|---|
| Company Name:                                | Durham PAT Testing                                    |            |   |
| Address:                                     | 21 Leesfield Road<br>Meadowfield<br>Durham<br>DH7 8NJ | Telephone: | 0191 3781189  |
|  |   | Mobile:    | 07512303393   |
|  |   | Email:     | info@durhampattesting.co.uk   |
| Cert Number:                                 | 007035  | Signature: |  |
| Order Number:                                | 7463  |            |   |
| File Name:                                   | Robinson House 16-08.PAT                              |            |   |

| PAT TESTER DETAILS |                    |                    |                      |
|--------------------|--------------------|--------------------|----------------------|
| Serial Number      | Make and Model     | Certificate Number | Calibration Due Date |
| 06K-0502           | Seaward Apollo 600 | BTM13808           | 21/05/2025           |

# PAT Report Passes And Fails For all Sites and Locations

| CLIENT DETAILS |  |
|----------------|--|
| Company Name:  | Believe Housing                                  |
| Address:       | Robinson House<br>Park Lane<br>Horden<br>SR8 4DD |



| DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING |   |            |                             |
|--|---|------------|-----------------------------|
| Company Name:                                | Durham PAT Testing                                    |            |                             |
| Address:                                     | 21 Leesfield Road<br>Meadowfield<br>Durham<br>DH7 8NJ | Telephone: | 0191 3781189                |
|  |   | Mobile:    | 07512303393                 |
|  |   | Email:     | info@durhampattesting.co.uk |
| Cert Number:                                 | 007035  | Signature: |                             |
| Order Number:                                | 7463  |            |                             |
| File Name:                                   | Robinson House 16-08.PAT                              |            |                             |

| PAT TESTER DETAILS |                    |                    |                      |
|--------------------|--------------------|--------------------|----------------------|
| Serial Number      | Make and Model     | Certificate Number | Calibration Due Date |
| 06K-0502           | Seaward Apollo 600 | BTM13808           | 21/05/2025           |

| APPLIANCE DETAILS AND TEST RESULTS                             |                         |           |        |          |                         |                    |            |              |                    |    |
|--|-------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|--------------------|----|
| Key<br>P = PASS / F = FAIL / S = SKIP (or test not applicable) |                         |           |        |          |                         |                    |            |              |                    |    |
| Appliance Id   | Appliance Description   | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status     |    |
| <b>ROBINSON HOUSE - KITCHEN</b>                                |                         |           |        |          |                         |                    |            |              |                    |    |
| 465605   | MATSUI FRIDGE FREEZER   | 16/08/24  | P      | S        | P 0.12                  | P 19.99            | S          | S            | PASS               |    |
| 465606   | BUSH FREEZER            | 16/08/24  | P      | S        | P 0.30                  | P 19.99            | S          | S            | PASS               |    |
| 465607   | CYGNET BOILER           | 16/08/24  | P      | S        | P 0.10                  | P 19.99            | S          | S            | PASS               |    |
| 465608   | MORPHY RICHARDS TOASTER | 16/08/24  | P      | S        | P 0.11                  | P 19.99            | S          | S            | PASS               |    |
| 465609   | BINGO MACHINE           | 16/08/24  | P      | S        | S                       | P 19.99            | S          | S            | PASS               |    |
| 465610   | TEAM BREAD MAKER        | 16/08/24  | P      | S        | P 0.09                  | P 19.99            | S          | S            | PASS               |    |
| 465611   | 4 WAY EXTENSION         | 16/08/24  | P      | P        | P 0.02                  | P 19.99            | S          | S            | PASS               |    |
| 465612   | COOKWORKS KETTLE        | 16/08/24  | P      | S        | P 0.11                  | P 19.99            | S          | S            | PASS               |    |
| 465613   | LAMONA COOKER           | 16/08/24  | P      | S        | P 0.38                  | P 19.99            | S          | S            | PASS               |    |
| 465614   | LAMONA MICROWAVE        | 16/08/24  | P      | S        | P 0.12                  | P 19.99            | S          | S            | PASS               |    |
| 465615   | LAMONA COOKER           | 16/08/24  | P      | S        | P 0.18                  | P 19.99            | S          | S            | PASS               |    |
| 465616   | MORPHY RICHARDS TOASTER | 16/08/24  | P      | S        | P 0.11                  | P 19.99            | S          | S            | PASS               |    |
| 465617   | INTEGRATED HOOD         | 16/08/24  | P      | S        | S                       | P 19.99            | S          | S            | PASS               |    |
|  |                         |           |        |          |                         |                    |            |              | Total Appliances > | 13 |
| <b>ROBINSON HOUSE - LOUNGE</b>                                 |                         |           |        |          |                         |                    |            |              |                    |    |
| 465618   | MEDIA HIFI              | 16/08/24  | P      | S        | S                       | P 19.99            | S          | S            | PASS               |    |
| 465619   | LG TELEVISION           | 16/08/24  | P      | S        | S                       | P 19.99            | S          | S            | PASS               |    |
|  |                         |           |        |          |                         |                    |            |              | Total Appliances > | 2  |
| <b>ROBINSON HOUSE - OFFICE</b>                                 |                         |           |        |          |                         |                    |            |              |                    |    |

**APPLIANCE DETAILS AND TEST RESULTS**

**Key**

P = PASS / F = FAIL / S = SKIP (or test not applicable)

| Appliance Id | Appliance Description      | Test Date | Visual | Polarity | Earth Continuity (Ohms) | Insulation (MOhms) | Load (kVA) | Leakage (mA) | Overall Status |
|--------------|----------------------------|-----------|--------|----------|-------------------------|--------------------|------------|--------------|----------------|
| 470256       | PHONE POWER SUPPLY UNIT    | 03/09/24  | P      | S        | S                       | S                  | S          | S            | PASS           |
| 470257       | CLASS 1 POWER LEAD         | 03/09/24  | P      | P        | P 0.05                  | P 19.99            | S          | S            | PASS           |
| 470258       | CLASS 1 POWER LEAD         | 03/09/24  | P      | P        | P 0.05                  | P 19.99            | S          | S            | PASS           |
| 470259       | LAPTOP POWER SUPPLY UNIT   | 03/09/24  | P      | S        | S                       | P 19.99            | S          | S            | PASS           |
| 470260       | LAPTOP POWER SUPPLY UNIT   | 03/09/24  | P      | S        | S                       | P 19.99            | S          | S            | PASS           |
| 470486       | 6 WAY EXTENSION            | 03/09/24  | P      | P        | P 0.08                  | P 19.99            | S          | S            | PASS           |
| 470487       | POWER SUPPLY UNIT          | 03/09/24  | P      | S        | S                       | S                  | S          | S            | PASS           |
| 470488       | USB ADAPTER                | 03/09/24  | P      | S        | S                       | S                  | S          | S            | PASS           |
| 470489       | POWER SUPPLY UNIT          | 03/09/24  | P      | S        | S                       | S                  | S          | S            | PASS           |
| 470490       | POWER SUPPLY UNIT          | 03/09/24  | P      | S        | S                       | S                  | S          | S            | PASS           |
| 470491       | CLASS 1 POWER LEAD         | 03/09/24  | P      | P        | P 0.03                  | P 19.99            | S          | S            | PASS           |
| 470492       | LAPTOP POWER SUPPLY UNIT   | 03/09/24  | P      | S        | S                       | P 19.99            | S          | S            | PASS           |
| 470493       | BATTERY POWER SUPPLY UNIT  | 03/09/24  | P      | S        | P 0.01                  | P 19.99            | S          | S            | PASS           |
| 470494       | GUARDIAN POWER SUPPLY UNIT | 03/09/24  | P      | S        | S                       | S                  | S          | S            | PASS           |

Total Appliances > 14

**Total Appliances For Report: 29**

# Certificate of Electrical Safety Testing

Certificate Number  
**007035**

## Certificate Issued To

Believe Housing  
Robinson House  
Park Lane  
Horden  
SR8 4DD

## Site Address (if different to Issued to Address)

ROBINSON HOUSE

**Valid Until: 16/08/2025**

All Portable Appliances have been inspected and / or tested in line with  
guidelines set out in the IET Code of Practice



## Certificate Issued By

Durham PAT Testing  
21 Leesfield Road  
Meadowfield  
Durham  
DH7 8NJ  
Phone: 0191 3781189  
Mobile: 07512303393  
Email: info@durhampattesting.co.uk

**DURHAM**  
**PAT TESTING**