SERVICE CERTIFICATE

CERTIFICATE No. 11003

Hutton Fire Protection Ltd.
Unit A, Vue Business Park, Ladysmith Street,
Hartlepool TS25 1PX
Tel: 01429 260 413
Website: www.huttonfireprotection.com
Email: hhutton@huttonfireprotection.co.uk

Hutton Fire Protection

INVOICE ADDRESS

BELIEVE HOUSING

LOCATION ADDRESS

FAIRGLOUGH COURT
PETERLEE

Invoice No. .....

Delivery/Service Date 30/4/26

Customer Order No. .....

DESCRIPTION	TOTAL SERVICED	CON'D	RECHARGED	O/A	PTR	O/A	NEW EQUIP	O/A
WATER 9L								
FOAM AFFF 1L								
FOAM AFFF 2L								
FOAM AFFF 3L								
FOAM AFFF 6L	2							
FOAM AFFF 9L								
CO_2 2kg	1							
CO_2 5kg								
CO_2 OTHER								
POWDER 1KG								
POWDER 2KG								
POWDER 4KG								
POWDER 6KG								
POWDER 9KG								
POWDER 12KG								
6LTR CLASS F								
3LTR WATER ADDITIVE								
6LTR WATER ~~ADDITIVE~~	1						1	
TOTAL EXTINGUISHERS	4						1	
TOTAL HOSE REELS								
TOTAL FIRE BLANKETS	1							

ENGINEERS COMMENTS

1x 6ltr Foam due ES - Replaced with 1x New 6ltr Water.

SPARE PARTS FITTED	QTY	O/S
HEADCAP ASSEMBLY	1	
HEADCAP SEAL	1	
HOSE/NOZZLE SEAL	3	
SAFETY CLIP/PIN	1	
VALVE ASSY (CO2)		
HORN ASSY (CO2)		
HOSE & HORN ASSY CO2		
TAMPER INDICATOR	4	
GAUGE TEST	3	
BURSTING DISC		
HOSE REEL NOZZLE		
WORM DRIVE CLIP		
CARTRIDGE 55GM		
CARTRIDGE 75GM		
CARTRIDGE OTHER		
WALL BRACKET		
EXTINGUISHER ID SIGN	1	
MISC. O. RINGS CO2	1	
EXTINGUISHER TESTED BY DISCHARGE		
ATTENDANCE FEE		
CALL OUT FEE		
DELIVERY CHARGE		
LABOUR		

TOTAL		
VAT		
TOTAL		

Engineer's Signature B. McMorris Print Name Ben McMorris

Customer's Signature N/A Print Name N/A

Position ..... Date Signed .....

SERVICE ☑

CALL OUT ☐

Customer Copy: White A/C: Blue

BAFE
Fire Extinguisher Service Provider (SP101)

Inspection by the user: It is recommended that regular visual inspections of all extinguishers be carried out by the user or by user's representative. The frequency of inspections by the user should be not less than monthly and, when circumstances require, inspections should be carried out more frequently. Apart from the non confirming extinguishers as recorded, all portable fire extinguishers have been inspected and serviced in accordance with BS503 PT9 and BS5306 Part 3. Terms Subject to HUTTON FIRE PROTECTION Standard published conditions of sale, applicable to the goods or services described above. Copy available on request.